

# **ADDENDUM NO. 2**

## **BID AND CONTRACT DOCUMENTS**

**FOR**

**BID No. 10P2**

**CHAFFEY COMMUNITY COLLEGE DISTRICT  
FONTANA CENTER EXTERIOR PAINTING  
FONTANA, CALIFORNIA  
COUNTY OF SAN BERNARDINO**



**Chaffey College**

CHAFFEY COMMUNITY COLLEGE DISTRICT  
5885 Haven Avenue  
Rancho Cucamonga, CA 91737

The following changes, additions, deletions, clarifications, or corrections shall become part of the Bid and Contract Documents for Chaffey Community College District Bid No. 10P2, Fontana Center Exterior Painting Project at the Fontana Campus, first advertised July 28, 2009. All other terms, specifications, and conditions remain the same. Each bidder is responsible for transmitting this information to all affected subcontractors and suppliers prior to the opening of bids. Each bidder shall acknowledge receipt of this Addendum on its Bid Form.

Modifications are identified by "clouds" and the following:      Deletions ~~striketrough~~  
Insertions/Substitutions *italic-underlined*.

Item 1:    **Add** the attached CONTRACTOR QUESTIONS AND ANSWERS (August 25, 2009), RFC # 10P2-1 through RFC# 10P2-2 to the end of the Instructions to Bidders.

**END OF ADDENDUM NO. 2**

**BID NO.: 10P2**  
**PROJECT NAME: FONTANA CENTER EXTERIOR PAINTING**  
**FONTANA, CALIFORNIA**

**CONTRACTOR QUESTIONS & ANSWERS (August 25, 2009)**

**RFC # 10P2-1**

**Question: Section 09-01-90, Section 3.03 Preparation of Existing Masonry surfaces. Is sandblasting the required method?**

Answer: As noted in the above-referenced paragraph, Contractor at his or her option shall "Power wash, sandblast or wire brush all areas to be painted..." Any of the three listed methods is acceptable.

**RFC # 10P2-2**

**Question: On sheet A1.1, on the legend there is a symbol for Landscape Bed, is that area to be LANDSCAPED? If yes there is no specs and call out for plant material or irrigation plans/as-builts. If NO is this area to be protect in place?**

Answer: This project is for exterior painting, so therefore, no new landscaping or irrigation is required. The patterned areas indicated in the legend as "LANDSCAPE BED" are there to simply to show the painting contractors where landscaped beds exist. Yes, these landscape beds will need to be protected in place.

**END OF SECTION**